



COMPACT APC20 DALI-2

Ceiling-mounted presence detector with integrated control unit
for DALI-2 devices

User manual

MA02254201 | 3.00 | EN

PERFORMANCE FOR SIMPLICITY

ESYLUX GmbH | info@esylux.de | www.esylux.de

Document	Version	Edition	Validity
MA02254201	3.00	20240722	F V2.0.2 A V1.8.17

© ESYLUX GmbH
An der Strusbek 40 | 22926 Ahrensburg | Germany

Subject to change without notice.

Reproductions, including translations into other languages or reuse of content for other purposes, may only be authorised by written consent from ESYLUX GmbH.

Table of contents

1	Introduction.....	6
1.1	Manufacturer/Contact	6
1.2	Product identification.....	6
1.3	Content and meaning of the document.....	7
1.4	Typographical conventions	8
2	Safety.....	9
2.1	Intended use	9
2.2	Staff qualifications	9
2.3	Safety instructions.....	9
3	Overview	11
3.1	Scope of delivery	11
3.2	APC technical data	11
3.3	System overview	15
3.4	Features and advantages of the APC.....	16
3.5	Features and advantages of the app	16
3.6	Declaration of conformity	17
3.7	Accessories.....	17
4	Installation	18
4.1	Mechanical work	18
4.2	Circuit diagram.....	19
4.3	Electrical work	20
4.4	Electrical work with WINSTA plugs	24
4.5	Insertion and alignment.....	25
4.6	Determining the direction of the sensors for detecting presence	27
4.7	Installing the app	28
4.8	Initial commissioning.....	29
4.9	Setup Wizard.....	30
5	Configuration	36
5.1	APC basics	36
5.1.1	Broadcast mode.....	36
5.1.2	Group operation.....	37
5.1.3	Light control	39
5.1.4	Minimum constellations.....	40
5.1.5	APC LED indicators.....	41
5.1.6	Timer function	42

5.2	App basics.....	44
5.2.1	Requirements for using the app.....	44
5.2.2	Identifying devices.....	44
5.2.3	Bluetooth connection.....	45
6	Settings menu.....	47
6.1	Overview.....	47
6.2	Setup Wizard.....	50
6.3	Manual setup.....	51
6.4	Address.....	52
6.5	Create groups.....	54
6.6	Configure groups.....	56
6.6.1	Operating mode.....	58
6.6.2	Light.....	62
6.6.3	Afterglow.....	72
6.6.4	Orientation light.....	74
6.6.5	Standby switch-off.....	76
6.7	Scenes.....	77
6.8	Group offset.....	81
6.9	Change over groups.....	84
6.10	Create swarms.....	91
6.11	Parameterise devices.....	92
6.11.1	Control gear (lighting).....	93
6.11.2	Motion sensors.....	93
6.11.3	Light sensors.....	95
6.11.4	Push-buttons.....	97
6.11.5	Switch.....	100
6.11.6	Actuator.....	102
6.12	Central button function.....	104
7	Products section.....	106
7.1	Products.....	106
8	Projects section.....	109
8.1	Overview.....	109
8.2	Create project.....	110
8.3	Change device settings in the project.....	112
8.4	Export and import project.....	113
9	Menu information.....	114
10	FAQ.....	116
10.1	What does this APC indicator mean?.....	116
10.2	What does this app indicator mean?.....	116
10.3	Why is a function or setting unavailable or greyed out?.....	117
10.4	How is the time set in the APC?.....	117

11 Decommissioning	118
11.1 Disassembly	118
11.2 Disposal	118
12 APPENDIX	119
12.1 Abbreviations	119
12.2 Glossary	120

1 Introduction

1.1 Manufacturer/Contact

If you have questions about the product, need help with the app or are planning extensions, do not hesitate to get in touch with us:

ESYLUX GmbH
An der Strusbek 40
22926 Ahrensburg
Germany

Phone: +49 4102 489-0
E-mail: info@esylux.com
Internet: www.esylux.com


1.2 Product identification

This document applies to the following products:

Item name	A	B	C	H	H _{max}	Item number
PD-C 360bt/8 APC20 PS plus DALI-2	8	6	4	3	5	EP10428272
PD-C 360bt/24 APC20 PS plus DALI-2	24	11	8	3	10	EP10428111
PD-C 360bt/32 APC20 PS plus DALI-2	32	11	8	3	10	EP10428289
PD-C 360bt/8 APC20 PS plus DALI-2 BK	8	6	4	3	5	EP10428876
PD-C 360bt/24 APC20 PS plus DALI-2 BK	24	11	8	3	10	EP10428883
PD-C 360bt/8 APC20 PS plus DALI-2 WIN-STA Codel	8	6	4	3	5	EP10428890
PD-C 360bt/24 APC20 PS plus DALI-2 WIN-STA Codel	24	11	8	3	10	EP10428906

A: Detection range transverse \varnothing [m]
B: Detection range frontal \varnothing [m]
C: Presence range \varnothing [m]
H: recommended mounting height [m]
H_{max}: maximum mounting height [m]

Detection ranges of the presence detector:



The name of the item contains important information about the product:

Element of the item name	Meaning
PD	Presence Detector device category
C	Compact series
360	Detection angle (in degrees)
bt	Configuration via Bluetooth and app
8/24/32	Detection range transverse (ø in meters)
APC20	Application Controller Variant
PS	Including power supply
plus	with HVAC contact
DALI-2	DALI-2 control system
BK	Plate colour black
WINSTA Codel	Connector WINSTA MIDI, Coding I

1.3 Content and meaning of the document

This document contains detailed information about the installation, configuration and complex functions of the product.

The current document is available for download as a PDF at www.esylux.com. It can be printed out if required.

- Read the document before using the product.
- Pay particular attention to the safety and warning instructions.
- If you have any questions, contact the manufacturer.
- Keep the document in a safe place.
- If other people use the product, give this document to them.

1.4 Typographical conventions

The following typographical conventions are used in this document:

Typographical depiction	Meaning
<Factory settings>	Menu, screen, button
[Fully automatic]	Condition, parameters
"Connection established"	Message, input
see 2 <i>Safety</i>	Cross-reference to chapter or section
1. ...	Binding sequence of actions
2. ...	
3. ...	
» ...	Action result

The warnings in this document have the following meanings:

WARNING

... warns of a hazard with a medium degree of risk.

Failure to observe may result in death or serious injury.

CAUTION

... warns of a hazard with a low degree of risk.

Failure to observe may result in moderate or minor injury.

NOTICE

... warns of possible property damage.

Failure to observe may result in damage to equipment or the environment.

In addition:

Information

Important or useful additional information

2 Safety

2.1 Intended use

This product is a DALI-2 certified ceiling-mounted presence detector with integrated DALI-2 controller for room-wide light control of a maximum of 16 groups. Configuration is done via an app.

The product may only be used as follows:

- The product is intended exclusively for indoor use and ceiling mounting with fixed installation.
- The product is designed for the use DALI-2 components in the DALI-2 bus.
- The maximum number of DALI-2 components that can be connected and the operating conditions must be observed. For details see *3.2 APC technical data*.
- The use of unsuitable components, modifications to the product and unauthorised repairs are not permitted.
- The product may only be used if it is in technically fault-free condition.

In the event of improper use, the manufacturer generally excludes any resulting personal injury or property damage.

2.2 Staff qualifications

Installation, commissioning and other work on the 230 V mains may only be carried out by electricians or electrical specialists in keeping with the country-specific regulations.

Configuration and operation can also be performed by individuals with no electrical engineering qualification.

- If you need assistance with the configuration, contact an electrical fitter or a qualified electrician.

2.3 Safety instructions

Installation, commissioning and other work on the 230 V mains may only be carried out by electricians or electrical specialists in keeping with the country-specific regulations.

The connection must be protected with a 10 A circuit breaker.

Nevertheless, there are the following residual risks:

 **WARNING**

Risk of fatal injury from electric shock.

Working on the 230 V mains can result in death or serious injury.

- Always observe the 5 safety rules:
 1. Switch off.
 2. Secure against being switched on again.
 3. Make sure that no voltage is present.
 4. Earth and short-circuit.
 5. Cover adjacent live parts.

 **WARNING**

Risk of fatal injury from interfering with the device.

Opening and modifying the device can result in death or serious injury – also for any others working on the system.

- Only remove the connection cover of the Powerbox for installation.

 **CAUTION**

Risk of injury due to improper installation.

When inserting the device into the installation opening, the raised mounting springs may snap back.

- Do not release the mounting springs before inserting them into the installation opening.

NOTICE

Risk of damage due to faulty connection.

Reversed polarity or short circuit of the bus line can result in malfunctions or damage to the components.

- Observe the DALI-2 specifications (IEC 62386).
- Only use bus cables (not included) for all DALI-2 connections in accordance with DALI-2 specifications.

NOTICE

Risk of damage due to improper cleaning.

Cleaning with alcohol-based, corrosive or abrasive cleaning agents or scouring pads can damage the surface and lens of the device and cause malfunctions.

- Use a soft cloth dipped in detergent solution for cleaning.

3 Overview

3.1 Scope of delivery

The product scope of delivery comprises:

- Device
 - Sensor unit (controller)
 - Powerbox with power supply and push-button interface
 - 180° lens mask
- Cable tie for tension relief
- Brief instructions for installation and commissioning

3.2 APC technical data

APC20	
General	
Device category	Ceiling-mounted presence detector with integrated DALI-2 control unit and power supply
Control system	DALI-2 bus
Status signalling	Multicolour LEDs
User interface	ESY app
User interface	Bluetooth (BLE)
Bluetooth range approx.	10 m
Ambient temperature	0-40 °C
Relative humidity	5-93%, non-condensing
Conformity	CE, EAC, RoHS, WEEE

APC20

Mounting / Connection	
Mounting type	Ceiling installation
Mounting location	Soundproof ceiling
Installation opening \varnothing	68 mm
Ceiling thickness max.	40 mm
Installation depth	80 mm + bending radius of installation cable
Standard connection type	Plug-in terminal
Connectable conductor cross-section	0.5-2.5 mm ²
Model WINSTA Code I connection type	Connector
Connector system	WINSTA MIDI, Cod. I, 5-pole (1.5 mm ²)
Bus cable length max.	300 m (conductor cross-section \geq 1.5 mm ²)
Cable length to a push-button/switch max.	30 m
Housing	
Outer diameter \varnothing	108 mm
Housing height	118 mm – 126 mm – 126 mm *
	* each for model /8 – /24 – /32
Weight	237 g
Material	UV-stabilised polycarbonate
Colour	white, similar to RAL 9010
Protection class	IP20
Electrical layout	
Mains voltage	230 V AC \pm 10%
Mains frequency	50-60 Hz
Starting current	20 A / 110 μ s
Power consumption	5.0 W
Power consumption max. DALI load	3.7 W
Standby consumption	<0.4 W
Protection class	II


APC20	
Control system/bus system	DALI-2 (IEC 62386)
DALI output voltage	16 V DC
External power supply possible	9.5-22.5 V DC
DALI guaranteed output current	240 mA
DALI maximum output current	250 mA
DALI no-load current	2 mA
DALI quiescent current input	1.9 mA
DALI start-up time	600 ms
Push-button/switch connections	4x (non-floating)
Push-button/switch connections, potential	230 V AC
Actuator connection	1x (potential-free, switches at zero crossing)
Actuator connection, potential max.	250 V AC / 24 V DC
Actuator connection, current max.	10 A
Motion sensor	
Principle	Passive infrared (PIR)
Warm-up time	25 s
Detection angle	360°
Detection range transverse ø	8 m – 24 m – 32 m *
Detection range frontal ø	6 m – 11 m – 11 m *
Presence range detection range ø	4 m – 8 m – 8 m *
Max. detection area	50 m ² – 452 m ² – 804 m ² *
Recommended mounting height	3 m – 3 m – 3 m *
Maximum mounting height	5 m – 10 m – 10 m *
	* each for model /8 – /24 – /32
Range adjustment	mechanically, by means of cut-to-size lens mask
Light sensor	
Light measurement	Mixed light
Brightness range	5-2000 lx

APC20


Functionality	
Configurable control gear (-102) max.	64
Configurable sensors (-103) max.	24
Configurable groups max.	16
Configurable scenes max.	16
Operating mode	Fully automatic, semi-automatic, manual operation, brightness automatic, staircase automatic
Constant light control	+
Group offset	+
Manual adjustment of brightness setpoint	+
Afterglow	+
Orientation light	+
Flexible group switching	+
Switching of external lighting and HVAC	+
Standby switch-off	+
Swarm function	+
Central function	+
Timer function	+
HCL/ SymbiLogic	-
Night operation	-
Alarm operation	-

3.3 System overview

Example connection diagram for an APC application with a BMS:



DALI-2 bus participants and bus communication between APC and BMS:



-101 - -304 Standards part of IEC 62386
 * Not available in the model COMPACT MINI BMS DALI-2

3.4 Features and advantages of the APC

The APC offers the following features and applications:

- DALI-2 certified ceiling-mounted presence detector with integrated DALI-2 control unit and power supply
- Presence and daylight-dependent constant light control for maximum energy efficiency
- Room-wide light control of up to 16 groups
- Wide range of manual override options and up to 16 scenes
- Easy adaptation to individual and complex room situations
- Automatic switching of groups when room use changes
- Fast start-up with factory settings in broadcast mode
- Individual groups immediately ready for operation with factory settings
- Status signalling by multicolour LEDs for all operating states and sensor actions
- 4 inputs for external push-buttons/switches (non-floating)
- Relay for switching (max. 10 A) external lighting and HVAC, and for standby switch-off
- Wide range of functions with Staircase automatic, for example
- Combination with timer functions

3.5 Features and advantages of the app

The app offers the following features and applications:

- Simple and comprehensive configuration of the APC via the bidirectional Bluetooth interface
- No internet access required for all relevant configuration steps
- Clear menu with self-explanatory structure and easy-to-understand operating elements
- Setup Wizard and practical user guidance through the entire configuration process
- Context-dependent information texts and explanatory diagrams for most menu items
- Situation-dependent feedback for missing information or impossible combinations
- Simple administration and documentation of configured projects as PDF reports
- Free download and regular updates via your app store

3.6 Declaration of conformity

We, the company ESYLUX GmbH, hereby declare that the product complies with the following requirements:

- Directive 2014/53/EU (Radio Equipment Directive)
- Directive 2011/65/EU (RoHS Directive)

The complete document is available for download as a PDF file:

https://www.esylux.com/ce/esylux_ce_pd-c_dali-2_apc_ce01994400.pdf

In the event of modification or extension of the product not agreed with us, this declaration shall lose its validity.

3.7 Accessories

The following accessories are available for this product:

Item name	Description	Item number
COMPACT APC Mounting Box IP20 SM WH	Surface Mounting Box IP20 for COMPACT APC DALI-2, white	EP10426278
COMPACT APC Mounting Box IP20 SM BK	Surface Mounting Box-C IP20 for COMPACT APC DALI-2, black	EP10426285
COMPACT APC Mounting Box IP54 SM GY	Surface Mounting Box IP54 for COMPACT APC DALI-2, grey	EP10427183
COMPACT APC Mounting Box IP54 SM BK	Surface Mounting Box IP54 for COMPACT APC DALI-2, black	EP10427190
COMPACT Cover Set 24/32 BK	Cover set for COMPACT series, 24 m/32 m, consisting of cover plate and design ring, black	EP00007491
COMPACT Cover Set 24/32 SR	Cover set for COMPACT series, 24 m/32 m, consisting of cover plate and design ring, silver	EP10425431
Basket Guard Round Large	Basket guard for presence and motion detectors as well as smoke detectors, diameter 180 mm, height 90 mm	EM10425608
Push Button x2 DALI-2 WH	2-way Push Button for DALI-2	EP10431609
Push Button x4 DALI-2 WH	4-way Push Button for DALI-2	EP10431616
Push Button x6 DALI-2 WH	6-way Push Button for DALI-2	EP10431623
Push Button x8 DALI-2 WH	8-way Push Button for DALI-2	EP10431630

4 Installation


4.1 Mechanical work

Description

The device is intended for mounting in the ceiling panel of a suspended ceiling.

Requirements

- The mains cable and the DALI-2 bus cable as well as any cables of external push-buttons/switches and actuator components have been prepared.
- There are no cables in the mounting area that could be damaged during drilling.
- The installation dimensions shown can be adhered to.




The required clearance above the Powerbox depends on the bending radius of the installation cables (example: 55 mm).

Procedure

1. Drill the installation opening in the ceiling panel.
2. Guide the installation cables downwards through the installation opening.
It is best to insert the device into the installation opening only after the installation lines have been connected.

4.2 Circuit diagram

Example circuit diagram for an APC application:



COMPACT APC DALI-2	APC DALI-2
L/N	Mains (230 V AC)
DA+/DA-	DALI-2 bus
K1/K2	External actuator component (floating)
S1-S4	External push-buttons/switches (non-floating)
Control Gear (Driver)	Example of a DALI control gear (lighting)
DA1/DA2	DALI-2 bus
DALI-2 BMS Sensor	Example of a BMS DALI-2
DA1/DA2	DALI-2 bus
S1/S2	External push-buttons/ switches (floating)

4.3 Electrical work

⚠ WARNING



Risk of fatal injury from electric shock.

Working on the 230 V mains can result in death or serious injury.


- Always observe the 5 safety rules:
 1. Switch off.
 2. Secure against being switched on again.
 3. Make sure that no voltage is present.
 4. Earth and short-circuit.
 5. Cover adjacent live parts.

Procedure


1. Remove the connection cover from the Powerbox. Loosen the screws as shown in the illustration.




2. Remove the covers in the connection cover at the points where cables are to be fed through.




3. Remove the insulation on each of the sheathed cables and the individual wires.




4. Take note of the order in which they are connected:
- **A:** If external push-buttons/switches (on S1-S4) or actuator components (on K1/K2) are used, connect these lines first.
 - **B:** Connect the DALI-2 bus cable (to DA+/DA-).
 - **C:** Connect the mains cable (to L/N).



5. If necessary, route a protective earth conductor via a separate terminal.



6. Use the included cable ties to secure the cables to the Powerbox for strain relief.



7. Put the connection cover back on the Powerbox and screw it tight.

4.4 Electrical work with WINSTA plugs

Requirements

⚠ WARNING


Risk of fatal injury from electric shock.

Working on the 230 V mains can result in death or serious injury.

- Always observe the 5 safety rules:
 1. Switch off.
 2. Secure against being switched on again.
 3. Make sure that no voltage is present.
 4. Earth and short-circuit.
 5. Cover adjacent live parts.

The installation requires some preparation:

- An on-site cable with WINSTA connectors
Type: WINSTA MIDI, Coding I, 5-pole (1.5 mm²)
Wire assignment: DA+, DA-, L, PE, N
- If required: Separate cables for external push-buttons/switches and actuator components




Procedure

1. Connect the WINSTA plug of the device to the WINSTA socket of the on-site cable.
2. If required: Connect the cables for external push-buttons/switches and actuator components to the connection box of the device.
Wire assignment: S1-S4 or K1/K2


4.5 Insertion and alignment

1. Write down the PIN code on the sticker on the device. You will need the PIN code later to register the device in the app.
You can also remove the sticker and affix it to your project documents.



2. Insert the device - with the mounting springs folded up - into the installation opening.

CAUTION! Risk of injury due to improper installation. When inserting the device into the installation opening, the raised mounting springs may snap back. Do not release the mounting springs before inserting them into the installation opening.



- » The mounting springs spread above the ceiling panel; this fixes the device in place.
3. If necessary, use the 180° lens mask.
Unscrew the plate (bayonet catch) and remove it. Put the lens mask on the sensor unit, put the plate back on and screw it tight.

4.6 Determining the direction of the sensors for detecting presence


Applies to PD-C 360bt/24 and PD-C 360bt/32:

The presence detector has 4 passive infrared sensors (PIR) for detecting presence. These are displayed in the app as 4 presence detector instances. If faulty switching occurs from a certain direction of detection, it may be necessary to deactivate a presence detector instance or reduce the sensitivity.

The direction of detection of the presence detector instances can be determined as follows:


Presence detector instance 8

View: Cable tie and mounting spring




Presence detector instance 9

View: Connection cover, left




Presence detector instance 10

View: Connection cover and mounting spring



Presence detector instance 11

View: Connection cover, right



4.7 Installing the app

Description

To use the app, you need a Bluetooth-enabled mobile device (smartphone or tablet) with Android or iOS. You can download the app from the Google Play Store or the Apple App Store.

PRIVACY NOTICE: The data used by the app is not stored or used outside the mobile device.

NOTE: The exact name of the settings below may differ depending on the Android or iOS version.

Requirements

Android

- Version: Android 8.0 or later
- Activate/allow system settings:
 - Bluetooth (BLE 5.0)
 - Wi-Fi or mobile data
- Grant app permissions:
 - Place of Installation
 - Memory

Apple iOS

- Version: iOS 11.0 or later
- Activate/allow system settings:
 - Bluetooth
 - Wi-Fi or mobile data

Procedure

- Install the ESY app.
- Open the app.

NOTE: The app is being continuously improved, meaning that new versions (updates) will be available in future.

- On Android mobile devices, you can set whether updates are automatically applied when the app is started or whether you have to update the app manually in the Play Store.
- On Apple iOS mobile devices, you can set how apps are updated in the App Store settings. Check the App Store to see if the latest version is installed.

4.8 Initial commissioning

Description

After completion of the mechanical and electrical work, initial commissioning should be carried out as a functional test.

Requirements


- Connecting the mains voltage poses no risk.
- The current version of the ESY app is installed.
For details see *4.7 Installing the app*.
- Bluetooth is turned on on the smartphone.
- The app has been started.

Procedure

- Switch on the mains voltage for this circuit.
- Wait approx. 30 s until the APC is ready for operation.
- Establish the Bluetooth connection between the app and the APC.
For details see *5.2.3 Bluetooth connection*.

If the connection works:

- The Setup Wizard shows the options for configuring the APC.



Next steps

- You can now configure the APC.
For details see *6.2 Setup Wizard*.
- If you exit the Setup Wizard at this time, the APC will remain in broadcast mode.
For details see *5.1.1 Broadcast mode*.

4.9 Setup Wizard


Description

The <Setup Wizard> function is a handy tool. It can be used to safely carry out the first configuration during initial commissioning - or following a factory reset.

- If the APC has already been set up, the Setup Wizard is cancelled to prevent the existing configuration from being unintentionally overwritten.
- If you want to completely reconfigure the APC in any case, first perform a factory reset in the <Settings> menu.

App

The <Setup Wizard> function can be found at the top of the Setup Wizard screen.




The Setup Wizard goes through the following steps:

1. Connect
2. Address the units
3. Create the groups
4. Assign devices to groups
5. Define the operating mode of the group(s)


1. Connect

After starting the Setup Wizard, the app and APC first connect via Bluetooth.




2. Address the units

In this step, the DALI-2 bus is queried and the connected bus participants (devices) are addressed.



The participants identified on the DALI-2 bus and provided with an address are listed by category:


- APC DALI-2
- Control gear
- Input devices
- Actuators




- If you want to repeat the addressing process, first perform a factory reset in the <Settings> menu.

3. Create the groups

Create groups for participants to act in the same way within the group.



- Use the **+** button to create additional groups.
- Enter a meaningful name for the group name to make it easier to tell them apart later on.
A maximum of 16 characters can be used for a group name.



4. Assign devices to groups

Assign at least one group to each participant.

Step 4 | Assign participants to groups

Please assign at least one group to each participant.

0 1 2 3

Choose device type All

Device information

Device name Control gear

Floor - Room -

1. Establish connection

2. Addressing the devices

3. Creating the groups

4. Assign devices to groups

5. Set the operating mode of the group(s).

CANCEL BACK NEXT

– Select device, here: Control gear

Step 4 | Assign participants to groups

Please assign at least one group to each participant.

0 1 2 3

Choose device type All

Device information

Device name Control gear

Floor - Room -

1. Establish connection

2. Addressing the devices

3. Creating the groups

4. Assign devices to groups

5. Set the operating mode of the group(s).

CANCEL BACK NEXT


– Assign group, here: Group 2

- Use the buttons to select the device type and the respective participant – recognisable by the flashing icon.
- From the groups offered, select at least one group the device is to be assigned to.
- Enter a meaningful name for the device and enter the installation location of the device (floor and room).
Numerical values from -9 to 200 can be entered for floor and room.

5. Selecting the operating mode of the group

Select an operating mode for each group created:

- Fully automatic (default setting)
- Semi-automatic
- Manual operation



For details see *6.6.1 Operating mode*.

After setting the operating mode for each group, the Setup Wizard ends.

NOTE: With the Setup Wizard, all devices together with their instances (e.g. a presence detector with its motion and light sensors) are addressed and assigned to groups. This allows quick, basic configuration. Subsequently, individual instances can be configured specifically.

- Changes and additions to the configuration are made with the <Manual setup> function. For details see *6.3 Manual setup*.

5 Configuration

5.1 APC basics

5.1.1 Broadcast mode

Description

Broadcast mode is the default operating mode. This enables the quick commissioning of a simple lighting system without having to address bus participants or divide them into groups.

- The lighting is controlled fully automatically by presence detection. It can also be switched on or off using push-buttons.
- All bus participants communicate via a common signal.
- All control gear (lighting) are controlled in the same way.
- All input devices have the same rights. For example, presence detection of each presence detector instance has the same effect on the lighting. The same applies to button instances, for example.
- Creating a group automatically ends broadcast mode.

App

There are two ways to use broadcast mode.

a.: Non-addressed operation (during initial commissioning and after resetting to factory settings)

- It is not necessary to address the bus participants.
- Individual configuration of individual bus participants is not possible.
- Light control is only managed by APC's light sensor. Other light sensors cannot be used.
- Otherwise, only presence detector and push-button inputs are taken into account.
- The standard button functions apply to connected push-buttons:

Single keystroke	Switch light on/off
Long push-button action	Dim light up/down
Double push-button action	Return to automatic light control

b.: Addressed mode (for quick set-up)

- Addressing bus participants is possible. Broadcast mode is maintained even after addressing – provided that no groups are set up.
- After addressing, the input devices can be set up individually.

- External light sensors (e.g. in a BMS) must be explicitly set up for each device, otherwise they are ignored.
- For connected push-buttons, the standard button functions (see above) can be changed by configuration.

Ending broadcast mode:

- Creating a group automatically ends broadcast mode.

Restoring broadcast mode:

- Deleting the last configured group automatically restores broadcast mode.

The last configuration saved for broadcast mode is used.

Adjustable parameters

Separate parameter settings are possible for broadcast mode.

Parameter	Setting values	Default value
Brightness setpoint (for light control)	100-2000 lx	500 lx
Brightness switching value (without light control)	5-2000 lx	500 lx
Light output min.	0-100%	0%
Light output max.	0-100%	100%
Light output at start	10-100% (in 10% steps)	50%
Follow-up time	00:01 - 24:00	00:05

5.1.2 Group operation


Description

Group operation allows the individual grouping of lights in a room zone. The room zones and their groups can be located in one room, but they can also be set up over several rooms.

- To create groups, all bus devices are addressed and assigned to their respective groups.
- Up to 16 groups can be set up. Each group has its own operating mode. For details see *6.6.1 Operating mode*.
- Group operation and broadcast mode are mutually exclusive. For details see *5.1.1 Broadcast mode*.
- Depending on the desired operating mode of a group, certain components must or can be present and configured in the corresponding group. For details see *5.1.4 Minimum constellations*.

- Group functions can be supplemented by the <Group offset> function, in which the illuminance of individual groups of lights is differentiated using offsets when there is only one light sensor.
For details see 6.8 *Group offset*.
- Group functions can be supplemented by the <Change over groups> function, which allows light control to be adapted to changing room situations.
For details see 6.9 *Change over groups*.

Application example: Groups for room zones



- Light fixture (illuminance in %)
- Presence detector (e.g. one APC DALI-2, three BMS DALI-2)
- 👤 Person present
- 👤 No person present

Explanation: Each presence detector provides individual, presence- and day-light-dependent light control in its room zone. If no one is present, as in group 2, the lighting remains switched off.

5.1.3 Light control

Description

Basically, there are two ways the APC control can influence the lighting:

- **Open-loop control** (the standard case)
How it works: Lighting is regulated to a constant brightness level depending on the amount of daylight.
Relevant parameter: Brightness setpoint
Technical implementation: Brightness is continuously measured and compared to the brightness setpoint. Light output is continuously adjusted so that the difference between the measured brightness value and the brightness setpoint is minimised.
 - If the measured brightness level falls permanently below the brightness setpoint when presence is continuously detected (plus follow-up time), the light is switched on and light output is continuously controlled.
 - If the measured brightness level is permanently above the brightness setpoint, the light is switched off.
- **Without light control** (the exception)
How it works: Lighting is switched with a preset, adjustable light output.
Relevant parameter: Brightness switching value
Technical implementation: When open-loop light control is deactivated, the light is controlled to a defined light output.
 - If the measured brightness level falls permanently below the brightness switching value when presence is continuously detected (plus follow-up time), the light is switched on and controlled to the defined light output.
 - If the measured brightness level permanently rises above the brightness switching value when the light is switched on and presence is still detected (plus follow-up time), the light is not switched off.
 - If the measured brightness level is permanently above the brightness switching value when the light is switched off, the light is not switched on when presence is detected.

If there are several light sensors in a group, the average level of the measured brightness is used.

App

Light control is switched on and off in the <Light> menu. For details see *6.6.2 Light*.

Adjustable parameters

The parameters being set depend on whether light control is switched on. For details see *Automatic light control*.

5.1.4 Minimum constellations

Depending on the operating mode of a group, the following devices/instances must or can be present and configured in this group:

Operating mode	Presence detector	Light sensor	Push-buttons	Actuator	Control gear (lighting)
Fully automatic	●	●	–	●*	●*
Semi-automatic	●	●	●	●*	●*
Manual operation	–	–	●	●*	●*
Brightness automatic	–	●	–	●*	●*
Staircase automatic	●**	–	●**	●*	●*

● Absolutely necessary
 – Without effect
 * Control gear or actuator component required
 ** Presence detector or push-button required


For details see *6.6.1 Operating mode*.

Explanations

- When planning an operating mode, the required devices/instances must be physically installed and addressed in the bus. The device or one of its required instances must be assigned to the group.
- If a group is not assigned a light sensor, e.g. in an interior room, the lighting is controlled regardless of the brightness.
- If the requirements for semi-automatic operation are met, you can also implement fully automatic or manual operation. The reverse is not true.
- If the requirements for an operating mode are not satisfied, not all parameter fields are available in parameter dialogues. This is an indication of missing devices/instances.
- If you change the operating mode, the parameters irrelevant to the new operating mode are retained. They become active again when you switch back.
- **IMPORTANT:** If you remove a required participant (device/instance) from the group, this group changes to the next possible operating mode. This can entail certain restrictions.

5.1.5 APC LED indicators

Various states and situations of the configuration can be identified by the colour and the flashing behaviour of the integrated LED.



	Colour	Meaning
a	green	System starting (approx. 20 s)
b	green	Operation starting or BlueMode ending
c	green	Motion detected
d	turquoise	Motion detected, but motion sensor not assigned to a group
e	blue	BlueMode activated
f	blue	Software upload activated
g	blue	Bluetooth connection activated
h	purple	DALI-2 identification
i	red – blue	Error 0x31: RecoveryMode activated, software and Bluetooth deactivated <ul style="list-style-type: none"> Briefly disconnect APC from the mains, then pair it with the mobile device (Bluetooth) and update the software.
j	red – blue	Error 0x21: Bus voltage missing or short circuit in the bus cable <ul style="list-style-type: none"> Check voltage supply in the bus.
k	red	Reset to factory settings activated (approx. 2 s)

5.1.6 Timer function

Description

The timer function enables actions to be triggered depending on time. For each action, 28 time slots can be set within a week for each group.

The following actions for groups can be controlled with the timer function:


- Light: Operating mode, light control, setpoint/threshold, follow-up time, light output, minimum light output, maximum light output;
- Afterglow: On/Off, light output, follow-up time;
- Orientation light: On/Off, light output, brightness-dependent, threshold;
- Standby switch-off: Mode (permanently on/as required);

In addition, time-controlled

- scenes can be started and ended in certain groups;
- Group switching can be done.


App

Under Light, tap <Time-dependent changes>, then tap <ADD NEW TIMER>. Under Afterglow, Orientation light, Standby switch-off or in Scenes, simply tap <ADD NEW TIMER>.



To activate or deactivate a timer, tap the <Timer> slide switch.

To delete a timer, drag it to the left on the screen. Then tap on the trash can icon.



Make sure that time slots for the same actions or action types do not overlap. This can result in unforeseen behaviour. However, time slots can be contiguous. For example, one scene can merge seamlessly into another scene by setting the start time of the second scene to the end time of the first scene.

The <repetitive> switch defines whether a timer should be repeated on several days or whether it should run over several days:

<repetitive> switch	Function
Off	Timer runs continuously from the start time on the first selected day of the week to the end time on the last selected day of the week.
On	Timer runs on all selected days from the start time to the end time.

Some parameters are not available in all operating modes. If you use the timer function to switch the operating mode, select a basic operating mode in which all the required parameters are available. Use it to activate an operating mode in which these parameters have no function.

Example:

- One group should work in fully automatic mode from 7 a.m. to 6 p.m. on weekdays.
- At all other times, the group should work in manual operation.

To do this, proceed as follows:

1. Select the operating mode for the group [Manual operation].
2. Set the desired light output.
3. Tap on <Time-dependent changes>.
4. Tap on <ADD NEW TIMER>.
5. Set <Start> to [07:00] and <End> to [18:00].
6. Turn on the <repetitive> switch.
7. Select the days of the week <MON> to <FRI>.
8. Select the operating mode [Fully automatic], set all parameters as required.

5.2 App basics

5.2.1 Requirements for using the app

Communication between the app and APC requires a stable Bluetooth connection for the duration of the configuration.

Some functions such as manual downloads and software updates require an internet connection.

5.2.2 Identifying devices

Devices can be identified in the app via the following icons:

Icon	Comment
	Tap on the icon. The control gear or the actuator switches on and off alternately. At the same time, the colour of the icon changes between grey and red.
	Tap on the icon. The presence detector flashes. At the same time, the colour of the icon changes between grey and red. For more information on the colour and frequency of the presence detector flashing, see <i>5.1.5 APC LED indicators</i> . If a presence detector has more than one instance, the presence detector flashes the same way for each instance. The arrangement of the instances cannot be identified by this function. For more arrangement on the direction of instances, see <i>4.6 Determining the direction of the sensors for detecting presence</i> .
	Button instance not pressed or switch instance open
	Button instance pressed or switch instance closed

5.2.3 Bluetooth connection

Description

Configuration of the APC requires a Bluetooth connection between the app on your mobile device (smartphone or tablet) and the APC.


Requirements

- Bluetooth is activated on the mobile device.
- The APC is supplied with mains voltage and is ready for operation.
- The distance between the mobile device and the APC is max. 10 m with no obstructions (door, wall, ceiling).
- If possible, the APC is within line of sight so that you can monitor the LED displays.
If there are several APCs in an installation, stand directly below the APC in question if possible.
- For the first connection – during initial commissioning or after reinstalling the app: Have the PIN code of the APC ready. The PIN code can be found on the sticker of the APC.

IMPORTANT: Do not leave the Bluetooth range of max. 10 m while the connection is being established. This also applies whenever configuring the APC.

App

- Tap the  button ("No connection" shown).
- If a location permission notice appears, grant the appropriate permission.
- The <Bluetooth device overview> screen shows the devices within range via Bluetooth.



- Tap the line [APC]. If several APCs are displayed in an installation, select the line [APC] with the highest signal strength.
- When the <Bluetooth pairing request> window appears, enter the PIN code of the APC.
- The LED on the APC flashes with short blue pulses.
- Wait until all instructions have run their course.

If the connection is successful, a check is made to see whether updated software is available for the APC. Always install the latest software. The Setup wizard then appears. For details see *6.2 Setup Wizard*.


If no connection is established, open the Bluetooth settings of your smartphone and delete all APCs from known devices. Then start the connection with the ESY app again. Do not use the system functions of your smartphone for the connection, only use the ESY app.

6 Settings menu

6.1 Overview

Description

Two options are available when the  button is pressed:




- Screen without Bluetooth connection



- Screen with active Bluetooth connection

- If the app and APC are not yet connected via Bluetooth ("No connection" shown), go to the Bluetooth device overview, select a product and connect via Bluetooth. For details see *5.2.3 Bluetooth connection*.
- If the app and APC are already connected via Bluetooth (the device name is shown), go to the <Settings> menu.

App




The <Configure>  button takes you to the Setup Wizard screen. For details see [6.2 Setup Wizard](#).

The following information and settings are available in the <Settings> section:

- **Device information, location, name**
 - The APC's GTIN and UID is shown.
 - Entry of floor and room, if desired.
 - Change the device name, if desired.
- **DALI power supply**
 - Switch between internal or external power supply.
IMPORTANT: This requires special knowledge and measures for the power supply in the DALI-2 bus.
 - Status of the power supply shown.
 - Error check of the power supply shown.
- **APC LED indicators**
 - Activate or deactivate LED feedback on presence detection.
 - Set LED brightness, if desired.

- **APC software version**
 - Software version of the APC shown.
 - Check the software version and update if necessary. This requires internet access. In addition, you can choose whether or not you want to receive an update notice in the future when establishing a Bluetooth connection.



- **User Manual**
 - Download and view the current User Manual. This requires internet access.
- **Change PIN**
 - Enter a new PIN code for the APC, if desired. Make a note of the new PIN code in your project documents.
- **Reset PIN to factory default**
 - Reset the PIN code for the APC to the PIN code printed on the sticker.
- **Device restarts**
 - The APC software is restarted. All custom settings are retained. The Bluetooth connection must then be re-established. For details see 5.2.3 *Bluetooth connection*.
- **Reset to factory settings**
 - The software of the APC is reset to factory settings. ATTENTION: All custom settings (parameters, groups, scenes, etc.) will be deleted. The Bluetooth connection must then be re-established. For details see 5.2.3 *Bluetooth connection*.

- **Disconnect**
 - The Bluetooth connection between the app and APC is disconnected.
The Bluetooth connection must then be re-established. For details see 5.2.3 *Bluetooth connection*.

6.2 Setup Wizard

Description


Two functions are available for setting up the APC:

- Setup Wizard
- Manual setup

App

You can access the Setup Wizard automatically during initial commissioning – or following a factory reset – as well as via the <Settings> menu.

The Setup Wizard screen is the main place to set up the APC.




6.3 Manual setup

Description

The <Manual setup> function is a flexible tool. With this tool – in addition to the Setup Wizard – special functions can be selected, activated or deactivated and settings can be made.

App

The <Manual setup> function can be found in the Setup screen below the Setup Wizard.



The following options are available with this function:

- Address
- Create groups
- Configure groups
- Scenes
- Group offset
- Change over groups
- Create swarms
- Parameterise devices
- Central button function

6.4 Address

Description


Addressing all of the bus participants is a requirement for a complete and successful configuration.

When addressing, each bus participant (device/instance) receives a unique identifier in the DALI-2 bus.

App


Two ways are available for addressing:

- Via the <Setup Wizard> function, e.g. after the initial commissioning or after a factory reset. For details see *4.9 Setup Wizard*.
- Via the <Manual setup> function, e.g. after connecting new bus devices or if the entire Setup Wizard does not need to be run through.



During addressing, the devices being addressed are listed:

- APC DALI-2
- Control gear
- Input devices
- Actuators



There are two options for addressing manually:

- **New installation**
All participants receive a new DALI-2 address. All previous addresses are deleted.
- **Subsequent installation**
Only newly added or previously unrecognised participants receive a new DALI-2 address. All other participants retain their address.

The address range can be defined for this purpose:

- Entire DALI-2 bus
- All control gear
- All input devices

At the end of addressing, the control gear switches to 100% light output, actuators (relays) switch on.

All addressed devices can then be configured.

- Check whether all installed devices have been found in the DALI-2 bus.
- If any devices are missing, check the electrical installation and carry out a subsequent installation.

If the addressing is incorrect, the control gear switches to 0% light output, actuators (relays) switch off.

6.5 Create groups

Description


The individual grouping of lights in a room zone permits group operation. For details see *5.1.2 Group operation*.

If no groups are created, the system is in broadcast mode. For details see *5.1.1 Broadcast mode*.


App

There are two ways to create groups:


- Via the <Setup Wizard> function, e.g. after the initial commissioning or after a factory reset. For details see *4.9 Setup Wizard*.
- Via the <Manual setup> function, e.g. after connecting new bus devices or if the entire Setup Wizard does not need to be run through.



After accessing the <Create groups> menu, the following options are available:



- Use the **+** button to create a new group.
For details see 3. *Create the groups.*
- With the function <Assign devices to groups> **+** you then assign each device at least one group.
For details see 4. *Assign devices to groups.*



- By swiping left, you can use the **🗑️** button to delete a group.

6.6 Configure groups


Description

All group-related settings can be made with the <Configure groups> function.


App

You get to the <Configure groups> menu from the <Manual setup> menu.

When accessing the menu, the following situations may occur:




- If no group is set up



- If a group has already been set up

- If no group is set up: Use the **+** button to create at least one group. Enter a meaningful name for the group name to make it easier to tell them apart later on. A maximum of 16 characters can be used for a group name.
- If a group is already set up: tap the **+** button and configure the group.




The following options are available for each of the groups:

- Configure devices in the group
For details see *6.11 Parameterise devices*.
- Configure light
- Afterglow
- Orientation light
- Standby switch-off

NOTE: Depending on the operating mode of a group, certain devices/ instances must be present and configured in this group. For details see *5.1.4 Minimum constellations*.

- If more groups are desired: Use the **+** button to create additional groups.



6.6.1 Operating mode

Description


- The operating mode is used to determine whether light control is to be fully automatic, started manually or manually alone.
- In broadcast mode, fully automatic operating mode applies to all bus participants.
- In group operation, an operating mode only applies to one group. This means that each group has its own operating mode.
- The operating mode can be changed depending on time.

Requirements

- Depending on the operating mode of a group, certain devices/instances must be present and configured in this group. For details see *5.1.4 Minimum constellations*.

App

The operating mode is set in the <Light> menu. For details see *6.6.2 Light*



Adjustable operating modes

Information

Specific parameters apply to each operating mode. Some parameters are not available in all operating modes.

- Check each time you change the operating mode whether the parameters set meet your requirements.
- If you use the timer function to switch the operating mode, select a basic operating mode in which all the required parameters are available. Use the timer function to activate an operating mode in which these parameters have no function. For details see *5.1.6 Timer function*.

Operating mode	Comment
Fully automatic	Lighting is automatically started by presence detection.
Semi-automatic	Lighting is switched on at the touch of a button and switches off automatically or at the press a button.
Manual operation	Lighting is switched on and off again at the touch of a button.
Brightness automatic	Light control is started automatically regardless of presence detection.
Staircase automatic	Lighting is switched on by presence detection or at the touch of a button and switches off again automatically.

Fully automatic

- Devices/instances required in the group:
 - Presence detector
 - Light sensor
- Lighting is automatically started by presence detection.
- As long as presence is detected, this state remains. Afterwards, follow-up time begins.
- Each presence detection restarts follow-up time.
- Important parameters:

Parameter	Unit	Comment
Brightness setpoint	lx (Lux)	for light control
Brightness switching value	lx (Lux)	without light control
Light output level	%	
Follow-up time	hh:mm	

For details on light control, see *Automatic light control*.

Semi-automatic

- Devices/instances required in the group:
 - Presence detector
 - Light sensor
 - Push-buttons
- The lighting is switched on at the touch of a button.
- As long as presence is detected, this state remains. Afterwards, follow-up time begins.
- Pressing the button has the following effect depending on current brightness:
 - measured brightness < brightness setpoint/brightness threshold: Manual override starts. For details see *5.1.3 Light control*.
 - measured brightness > brightness setpoint: Manual override starts. For details see *Manual brightness setpoint adjustment via push-button*.
- NOTE: Rapid changes in brightness may produce different results.
- Each presence detection or a new touch of a button restarts follow-up time.

- Important parameters:

Parameter	Unit	Comment
Brightness setpoint	lx (Lux)	for light control
Brightness switching value	lx (Lux)	without light control
Light output level	%	
Follow-up time	hh:mm	

Manual operation

- Devices/instances required in the group:
 - Push-buttons
- Lighting is switched on and off again at the touch of a button.
- The lighting remains in the selected state until the push-button is pressed again.
- Important parameters:

Parameter	Unit	Comment
Light output level	%	

Brightness automatic

- Devices/instances required in the group:
 - Light sensor
- Lighting is started regardless of presence detection.
- Important parameters:

Parameter	Unit	Comment
Brightness setpoint	lx (Lux)	
Minimum light output	%	
Maximum light output	%	

For details on light control, see *Automatic light control*.

Staircase automatic

- Devices/instances required in the group:
 - Push-button or presence detector
- The lighting is switched on when presence is detected or at the touch of a button.

- As soon as no presence is detected for the set follow-up time or no push-button is pressed, afterglow starts with reduced light output as a warning that the light will switch off. Afterglow cannot be deactivated. The lighting is switched off after the follow-up time of the afterglow has elapsed.
- The lighting cannot be switched off with a push-button. All push-buttons assigned to the group automatically have the [ON] function.
- Important parameters:

Parameter	Unit	Comment
Light output level	%	without light control
Brightness setpoint	lx (Lux)	for light control
Brightness switching value	lx (Lux)	without light control
Follow-up time	hh:mm	
Light output during afterglow	%	
Run-on time for afterglow	hh:mm	

6.6.2 Light

Description

In the <Light> menu, all group-related settings for operating mode, light values and light outputs can be made:

- Operating mode
- Automatic light control On/Off
- Brightness setpoint/brightness switching value
- Light output/Light output at start
- Setting brightness measurement
- Minimum light output, maximum light output
- Follow-up time
- Manual brightness setpoint adjustment


The following settings can be time-controlled:

- Operating mode
- Automatic light control On/Off
- Brightness setpoint/brightness switching value
- Light output/Light output at start
- Minimum light output, maximum light output
- Follow-up time

For more details on the timer function, see *5.1.6 Timer function*.

App

You get to the <Light> menu from the <Configure groups> menu.



Time-dependent changes

Most settings can be adjusted according to time.

For details see *5.1.6 Timer function*.


Operating mode

First select the desired operating mode. Available parameters for light control depend on the selected operating mode.

For details see *6.6.1 Operating mode*.

Automatic light control

Automatic light control can be activated or deactivated.



- Automatic light control activated
- Automatic light control deactivated
- Automatic light control activated:
Lighting is controlled to a constant brightness level – depending on the amount of daylight.
- Automatic light control deactivated:
Lighting is switched with a predefined, adjustable light output level.
For details see *5.1.3 Light control*.

Adjustable parameters for light control:

Parameter	Setting values	Default value
Brightness setpoint	100-2000 lx (in 10-lx steps)	500 lx
Light output at start	0-100% (in 10% steps)	50%
Follow-up time	00:01 - 24:00	00:05
Minimum light output	0-100%	0%
Maximum light output	0-100%	100%
Manual brightness setpoint adjustment via push-button	None, Temporary, Permanent	None


Adjustable parameters without automatic light control:

Parameter	Setting values	Default value
Brightness switching value	10-2000 lx (in 10-lx steps)	500 lx
Light output	0-100%	50%
Follow-up time	00:01 - 24:00	00:05

Brightness setpoint

The brightness setpoint is the target value of light control.

Brightness is continuously measured via light sensors and compared with the brightness setpoint. Light output is constantly adjusted so that the difference between the measured brightness and the brightness setpoint is minimised.



If required, the brightness measurement can be adapted to individual conditions. For details see *Setting brightness measurement*.


Brightness switching value

The brightness switching value is the value below which the lighting is switched on and above which the lighting is switched off.

If required, the brightness measurement can be adapted to individual conditions. For details see *Setting brightness measurement*.

Light output at start

Initial value of light output at the beginning of automatic light control. The system regulates up or down from this value after the light measurement has been completed.



NOTE: If <Light output at start> is set to [0%], the light output starts with an adaptively determined value.


Light output

<Light output> is used to set the light output if automatic light control is switched off.


NOTE: A value of [0%] is not accepted. The light output is then reset to the last set value.

Minimum light output, maximum light output

With <Minimum light output>, light output in automatic light control is limited downwards. Automatic light control will not fall below this minimum light output.




With <Maximum light output>, light output in automatic light control is limited upwards. Automatic light control will not exceed this maximum light output.



NOTE: Due to the limitation of light output, the actual brightness value in the room may fall below the legally prescribed values. If in doubt, verify compliance with these values by measuring the brightness.

Follow-up time

Time after the last presence detection during which the light remains switched on.




Subsequently, an afterglow can be defined.

Manual brightness setpoint adjustment via push-button


If the light is dimmed up or down manually during automatic light control, the new brightness value can be saved in the room as the new brightness setpoint.

Prerequisite: A push-button for dimming UP/DOWN has been defined.

With the [Temporary] setting, the new brightness setpoint is in effect until the end of current automatic light control. With a new presence detection, automatic light control starts again with the old brightness setpoint.




If set to [Permanent], the new brightness setpoint is in effect for all future automatic light controls.



In operating mode [Manual operation], the parameter <Manual setpoint adjustment via push-button> has a different function:

- With the [Permanent] setting, the light output dimmed with a push-button is saved permanently.
- With the [None] or [Temporary] settings, the light output set in the app is used again after switching off and on again.

Setting brightness measurement



This allows you to determine the optimal lighting at the intended workplace and ensure efficient light control.

Requirements:

- For the measurements you need a suitable illuminance measuring device ("luxmeter").
- The room must be completely darkened to obtain error-free measurements and optimal results.

Behaviour of the control system:

- In order to be able to optimally set the parameters for brightness measurement, the entire control system is stopped.
- The lights of the group to be set are switched to 100%. The remaining lights are switched to the minimum light value.
- As long as brightness measurement is active, the control system does not react to presence detection or manual push-button/switch commands.

Step 1: <Setting light sensors>

←
Setting brightness measurement

Group 1 - Group name 1

Step 1: Setting light sensors ↕

The setting of the light sensors will determine the reflection of the work surface to the respective light sensor via the correction factor.

Input device, Instance 3	☰
Measured illuminance	282 lx
Correction factor for brightness measurement	9
Assumed illuminance	2545 lx

Step 2: Weighting light sensors
→

Step 3: Measurement of illuminance
→


Calculated brightness value of the group:

2545 lx

Home
DALI-2 APC

With a correction factor for each light sensor, the measured value of the light sensor can be corrected to take into account the actual light reflections where the sensor is mounted.

- Measure the illuminance below the light sensor.



- Enter the measured value at the <Correction factor for brightness measurement> parameter.
This can be used to change the value for the assumed illuminance: Measured value x correction factor = assumed illuminance.
This value should be as close as possible to the measured illuminance.

Step 2: <Weighting light sensors>

The light sensors of the group can be freely weighted to prioritise the brightness values at different measuring points.


- It is recommended to weight measuring points in darker areas higher than light sensors in areas with more natural light.

NOTE: A maximum of four light sensors can be assigned to each group (e.g. two external light sensors in addition to two APC light sensors).

Step 3: <Measurement of illuminance>

The illuminance of the group must be determined in order to determine the external light component (e.g. incident sunlight).

- Measure the illuminance at the intended workstation (e.g. at the height of the desk surface).




- Enter the measured value in the parameter <Illuminance at workstation>.
- Enter the average ambient light exposure the light sensors in the group are exposed to in the <Amount of ambient light exposure> parameter. The amount depends on the room arrangement and the window areas. The higher the amount, the more the measured brightness value is corrected to ensure optimum light control at all times.

Room situation	Ambient light amount	Setting value
South side, many large windows	high	65-85%
East/West side, normal window areas	medium	35-65%
North side, a few small windows	low	>0-35%
no windows, inside, e.g. hallway	-	0%

6.6.3 Afterglow

Description

- Afterglow is not available in the following operating modes:
 - Manual operation
 - Brightness automatic
- Afterglow starts after the follow-up time of light control has elapsed.
- For the duration of afterglow, light output is controlled to an adjustable level.
- The duration of afterglow is controlled by a separate follow-up time.




- If light output before afterglow is set below the value set for afterglow, afterglow does not occur.
- In case of presence detection during afterglow, the previously used function is reactivated.
- Afterglow can be controlled with the timer function.

Requirements

- The group is in [Fully automatic], [Semi-automatic] or [Staircase automatic] operating mode.
- Afterglow must be activated. Afterglow is deactivated in the factory setting.


App




Adjustable parameters

Parameter	Setting values	Default value
Activate/deactivate afterglow	ON, OFF	OFF
Light output level	10-100% (in 10% steps)	10%
Follow-up time (afterglow duration)	00:01 - 24:00	00:05

- The light output of afterglow is usually below the standard light output.



- Afterglow duration determines how long – after the follow-up time – afterglow is activated.



6.6.4 Orientation light

Description

- The orientation light function is not available in the following operating modes:
 - Manual operation
 - Brightness automatic
- Orientation light is used as minimum lighting in a room when no presence is detected.
- Depending on operating mode, normal lighting is switched on as soon as presence is detected or a push-button is pressed.




- Orientation light can be switched on regardless of the brightness or switched on as required when there is not much light (setting [Brightness-dependent]). In the [Brightness-dependent] setting, orientation light is switched off if an adjustable brightness switching value is exceeded.
- Orientation light can be controlled with the timer function.

Requirements

- Orientation light must be activated. Orientation light is deactivated in the factory setting.
- The control system is in [Fully automatic], [Semi-automatic] or [Staircase automatic] operating mode.


App



Adjustable parameters


Parameter	Setting values	Default value
Activate/deactivate orientation light	ON, OFF	OFF
Light output level	5-50% (in 5% steps)	10%
Adopt as minimum for light control	ON, OFF	OFF
Brightness-dependent	ON, OFF	OFF
Brightness switching value (brightness-dependent)	100-2000 lx	100 lx

- Light output level: Light output defined for orientation light.



- Adopt as minimum for light control: Activates or deactivates the use of the light output of orientation light as the lower limit of light control and afterglow (if afterglow is activated).

- Brightness-dependent: Activates or deactivates brightness-dependent switching of orientation light.
- Brightness switching value: Brightness threshold at which the orientation light is switched on or off (if [Brightness-dependent] is activated).



6.6.5 Standby switch-off

Description

- The standby switch-off function enables the actuator to disconnect control gear from the power supply when it is not required. This makes it possible to reduce standby consumption in buildings.
- Standby switch-off can be controlled with the timer function. As the control gear can only be controlled following a delay after the power supply has been switched on, this function results in a loss of comfort. It is therefore recommended that standby switch-off is only used outside normal operating hours.

Requirements

- The actuator is configured for the relay function [Standby switch-off]. The switch-on delay is set. For details see 6.11.6 Actuator.

Adjustable parameters

Parameter	Setting values	Default value
Follow-up time	00:01 - 24:00	00:05
Standby switch off mode	depending on requirements, permanently on	depending on requirements

- The follow-up time should be longer than the follow-up time after the last presence detection, including any afterglow time.
- In standby switch-off mode [permanently on], the power supply is not switched off.

6.7 Scenes

Description


- A scene is activated via a push-button and accesses a predefined illumination level and actuator function.
- The control gear of the group is controlled with constant, adjustable light output.
- A scene can be used for several groups. Each group can be given individual parameters.
- No other functions are possible during the scene – except for manual override.
- A scene is ended by manual override, the [Automatic mode] button function or after the adjustable follow-up time has elapsed.
- Scenes can be defined depending on time.

Requirements


- The button instance that accesses the scene must be assigned to the relevant groups of this scene in order to start the scene in these groups. For details see *6.11.4 Push-buttons*.
- To use the actuator: An actuator with the relay function [Switch HVAC] must be assigned to the group.

App

You can get to the <Scenes> function from the Setup Wizard.




- Use the **+** button to create a new scene.
- Use the **➔** button to access a scene in order to edit it.



Settings to be made

Parameterise push-button:


To be able to start a scene, the function [Access scene] must be selected on the desired push-button for the single keystroke and the appropriate scene number must be set.



- Press the desired push-button to identify the appropriate instance. To identify the button instance the icon flashes 🖱️ 🔴🖱️ 🔴🖱️ 🔴🖱️.
- You can use the ⓘ icon to access further information.

Assign group:

A scene can be used for several groups. The groups relevant for the scene can be selected under <Assign group>.



Set light output and follow-up time:

The light output can be set for each group assigned to the scene. Optionally, [Follow-up time] can be used to set how long the group should remain switched on after the start of the scene. When set to [00:00], the lighting remains on until the scene is ended with a push-button.

The settings for the scene can be restricted to certain times. To do this, tap [ADD NEW TIMER].

For details see *5.1.6 Timer function*.

Adjustable parameters

Parameter	Setting values	Default value
Light output level	0..100 %	100 %
Follow-up time	00:00...24:00	00:00
Actuator	ON, OFF	ON

6.8 Group offset

Description


- For automated lighting control, one presence detector with light sensor is usually installed per area.
- For optimal energy efficiency, it may be necessary, even with only one measuring point (light sensor), to step down the illuminance of individual light groups by means of offsets.
- Lights near and far from windows are divided into groups and a control offset between the groups is set up using the <Group offset> function.
- The main group determines light control. The subgroups follow the main group and adopt the parameters of the main group.
- In daylight, the light output of the lights near the window is reduced more than the light output of the lights far from the window.

Requirements

- The main group has a light sensor instance.
- At least one other group is configured as a subgroup.

App

You can get to the <Group offset> function from the Setup Wizard.




The following options are available here:

- Groups -> Subgroups:
Existing groups can be converted into subgroups. Subgroups lose their set parameters and adopt the parameters of the main group.


- Subgroups -> Groups:
Subgroups can be converted back into normal groups. Parameters that have already been set are not adopted.

NOTE: The sum of all main groups and subgroups can be a maximum of 16.

IMPORTANT: A group with a light sensor instance must be selected as the main group.



The offset parameters must be set for these groups.




Adjustable parameters

Parameter	for main group light output	Setting values	Default value
High offset	75 %	-50...+20 %	0 %
Low offset	25 %	-20...+50 %	0 %


With the default values (high offset 0%, low offset 0%), the light outputs of the main group and subgroups are identical.

Resulting light control depending on the incidence of daylight:



- Light output of main group (lights far from window)
- Light output subgroups (lights near window), example:
 - high offset -20%
 - low offset -10%

Application example: Group offset near the window



- Light (light output in %)
- Presence detector (e.g. an APC DALI-2)

Explanation: Due to the offset between the groups, light output of the lights near the window is reduced more than the light output of the lights far from the window in daylight.

NOTE: The <Group offset> function can be combined with the <Change over groups> function. For details see [6.9 Change over groups](#).

6.9 Change over groups

Description

- If an area is used in different ways, the <Change over groups> function can be used to flexibly switch the division into groups depending on the respective application scenario.
- A switch is used to activate and deactivate groups. Up to three switches can also be combined.
- A manually operated light switch or the contact switch of a partition wall, for example, can be used as a switch. For details see [6.11.5 Switch](#).
- Instead of physical switches, time-controlled switches (timers) can be set up as virtual switches.

Requirements


- If a physical switch is to be used, the button instance for this input is deactivated, i.e. **all three** button functions (<Single keystroke>, <Long push-button action> and <Double push-button action>) are set to [No function]. The switch instance for this push-button input is set to [Change over groups ON] or [Change over groups OFF]. For details see [6.11.4 Push-buttons](#).



- All groups that are to be used in an application scenario are created. For details see 6.5 Create groups.

App

You can get to the <Change over groups> function from the Setup Wizard.




Create group switch:

- Use the  button to add a new configuration.


Edit group switch:

- Use the  button to access a configuration for editing.



Include groups:

This is used to assign all groups that can be activated or deactivated in this configuration.




Switch selection:

This selects the switches to be used to activate or deactivate groups in this configuration. A maximum of three switches can be used in one configuration.

For physical switches, the switch function must be changed in the switch settings.

Configure switch:



The push-button inputs are assigned to the following instances of the APC:

Push-button input	Button instance*	Switch instance
S1	0	4
S2	1	5
S3	2	6
S4	3	7

* The button instance used must be deactivated.

If you select a time-controlled switch, e.g. [Time-controlled switch 1], you must set one or more timers for this switch. Tap the <CREATE NEW TIMER> button. For details see *5.1.6 Timer function*.

Use the <Switch status in timer> switch to set whether an open or closed switch position is sent to the <Change over groups> function.

Group scenarios:


The possible number of group scenarios depends on the number of assigned switch instances.

Number of switch instances	Number of switch positions	Number of group scenarios
1	2 (1 open + 1 closed)	2
2	2 x 2	4
3	2 x 2 x 2	8

NOTE: When a switch instance is removed from the switch selection, the associated group scenarios are removed.

Application example: Group switching


Situation 1: Conference room with closed partition wall



- Light
- Presence detector (e.g. an APC DALI-2, a BMS DALI-2)

Explanation: A closed partition divides a room into two halves. The lights and presence detectors in the two halves of the room are assigned to group 1 or group 2 accordingly. In each group there is individual light control.


Situation 2: Conference room with open partition wall



- Light
- Presence detector (e.g. an APC DALI-2, a BMS DALI-2)


Explanation: All lights and presence detectors of the room are additionally assigned to a group 3. When the partition wall is opened, groups 1 and 2 are deactivated and group 3 is activated at the same time via the push-button input of the presence detector (external push-button). Uniform light control takes place in the entire room.

NOTE: The <Change over groups> function can be combined with the <Group offset> function. For details see 6.8 *Group offset*.

Application example: Group switching with group offset**Situation 1: Classroom during teaching**

- Light (high illuminance)
- Light (dimmed illuminance)
- Presence detector (e.g. a APC DALI-2 on the left, a BMS DALI-2 on the right)

Explanation: In a classroom, groups 1 and 2 are active during normal teaching. A group offset is set between the two groups because the lights near the windows require less illuminance.

Situation 2: Classroom during a presentation

- Light (high illuminance)
- Light (dimmed illuminance)
- Light (dimmed to 0%)
- Presence detector (e.g. a APC DALI-2 on the left, a BMS DALI-2 on the right)

Explanation: When the light switch (external push-button) is pressed at the beginning of a presentation, groups 1 and 2 are deactivated and groups 3, 4 and 5 are activated at the same time. The illuminance of group 3 in the presentation area is dimmed to 0%. Groups 4 and 5 continue to work with group offset, but with a lower setpoint and thus with dimmed illuminance for the presentation.

6.10 Create swarms

Description

- Several groups can be combined into a swarm. As soon as the lighting in a triggering group is switched on by presence detection or a push-button, the lighting in executing groups is also switched on with a defined light output.
- As soon as the lighting in an executing group is switched on by presence detection or a push-button, this overrides the swarm function.
- Mutual dependencies can be flexibly configured.

Requirements

- At least two groups are created.

App

You get to the <Create swarms> function from the Setup Wizard.

1. Tap the <CREATE NEW SWARM> button.
2. Tap the button  next to <Triggering group(s)> and select one or more groups.
3. Tap the button  next to <Executing group(s)> and select one or more groups.
4. Tap the button  next to <Configure light output in swarm>. Set the light output in the swarm for each executing group. This light output applies to all swarms in which the group is involved as the executing group.
 - » The swarm has been configured.

6.11 Parameterise devices


Description

- In the <Parameterise devices> menu, devices/instances can be parameterised and assigned to the previously set up groups.
- Instances are partial components of a device that fulfil an independent function, e.g. presence detection, brightness measurement or push-button input.
- Instances do not have their own DALI-2 address, but use the address of the respective device.
- Instances are handled separately and can be assigned to different groups and functions.

App

From the <Parameterise devices> menu, you can edit the following devices/instances:

- Control gear
- Motion sensors
- Light sensors
- Push-button
- Switch
- Actuators



The number of devices/instances currently addressed in the DALI-2 bus is shown in brackets.


6.11.1 Control gear (lighting)

Description

- Control gear is the DALI designation for a light fitting, in particular for the electronic control gear (ECG) that acts as a bus device.
- A control gear is addressed in the DALI-2 bus as a single device. There are no instances such as a light sensor in an APC.

App

You can get to the <Control gear> screen from the <Parameterise devices> menu.



- When a control gear is identified, the icon flashes.
- You can use the icon to access the device information of the ECG for each control gear:
 - Short address
 - Manufacturer
 - GTIN
 - UID
- The and buttons can be used to access or hide other settings.

6.11.2 Motion sensors

Description

- The motion sensors in the APC detect the presence and movement of people in the room. They perform presence detection.
- The included 180° lens mask is used to limit the detection range. For details see *4 Installation*.
- The response behaviour, i.e. the sensitivity of the motion sensors, can be individually adjusted.


- Each time presence is detected, the APC provides feedback via the built-in LED display. The brightness of the LED display can be adjusted.
- LED feedback can also be deactivated. For details see *6 Settings menu*.
- The motion sensors are assigned to the following presence detector instances of the APC:

Motion sensor	Presence detector instance for PD-C 360bt/8 APC...	Presence detector instance for PD-C 360bt/24 APC... PD-C 360bt/32 APC...
1.	8	8
2.	–	9
3.	–	10
4.	–	11

The assignment of instances may differ for other input devices (e.g. BMS detectors). For more details, please refer to the respective user manual.

App

You can get to the <Motion sensors> screen from the <Parameterise devices> menu.



- When a presence detector instance is identified the  icon flashes.
- You can use the  icon to access further information.
- The  and  buttons can be used to access or hide other settings.

Adjustable parameters

The following settings can be made for each presence detector instance:

Parameter	Comment	Setting values	Default value
Movement LED response	This allows you to set the extent to which presence detection triggers an LED response from the APC.	ON, OFF	ON
LED brightness	This allows you to set the brightness the LED uses in responses.	10-100% (in 10% steps)	50%
Sensitivity	If external disturbances (radiators, air conditioning, etc.) produce faulty switching, the sensitivity of the sensors should be reduced.	10-100% (in 10% steps)	100%

6.11.3 Light sensors

Description

- The light sensors in the APC detect direct incident light and light reflected from the room at the installation site.
- The actual illuminance measured at the installation site can deviate from the assumed target illuminance at the intended workplace.
- To compensate for this, the measured value of the light sensors can be adjusted with the help of a correction factor.
- If a suitable illuminance measuring device ("luxmeter") is available, you can also carry out an exact brightness measurement at the workplace. For details see *Setting brightness measurement*.
- The light sensors are assigned to the following light sensor instances of the APC:


Light sensor	Light sensor instance with PD-C 360bt/8 APC...	Light sensor instance with PD-C 360bt/24 APC... PD-C 360bt/32 APC...
1.	9	12
2.	10	13

The assignment of instances may differ for other input devices (e.g. BMS detectors). For more details, please refer to the respective user manual.

NOTE: A maximum of four light sensors can be assigned to each group, i.e. two external light sensors in addition to the two APC light sensors.

App

You can get to the <Light sensors> screen from the <Parameterise devices> menu.



- When identifying a light sensor instance, the  icon flashes.
- You can use the  icon to access further information.
- The  and  buttons can be used to access or hide other settings.

Adjustable parameters

The following settings can be made for each light sensor instance:

Parameter	Default value for PD-C 360bt/8 APC...	Default value for PD-C 360bt/24 APC...	Setting value	Comment
Correction factor for brightness measurement	9.5	7.5	same as default value	The light sensor correctly reports the actual illuminance.
			less than default value	It is too bright at the light sensor. The measured value is corrected downwards.
			greater than default value	It is too dark at the light sensor. The measured value is corrected upwards.

6.11.4 Push-buttons

Description

- Push-buttons can be used, for example, to switch lights on or off, dim lights and access scenes.
- Up to 4 push-buttons can be connected to push-button inputs S1-S4 of the APC with one pole.
- The number of push-button inserts that can be used per APC depends on the design of each insert:

Push-button insert	Contacts	Usable per APC
Single push-button	1 NO contacts	4 piece
Double push-button	2 NO contacts	2 piece
Double rocker push-button	4 NO contacts	1 piece


- The push-button inputs are assigned to the following button instances of the APC:

Push-button input	Button instance
S1	0
S2	1
S3	2
S4	3

Additional push-buttons can be integrated via the DALI-2 bus. The assignment of the push-button inputs to the button instances may differ for other input devices (e.g. BMS detectors). For more details, please refer to the respective user manual.

App

You can get to the <Push-button> screen from the <Parameterise devices> menu.



- When a button instance is identified, the icon flashes 🖱️ 🔴 🖱️ 🔴.
- You can use the ⓘ icon to access further information.
- The ▶️ and ◀️ buttons can be used to access or hide other settings.

Different commands can be executed with one push-button:

- Single keystroke
- Long push-button action
- Double push-button action

Adjustable parameters

Different functions can be set for each command:

Command	Default value	Setting values	Function
Single keystroke	ON/OFF	ON/OFF	Switch light on or off.
		ON	Switch light on.
		OFF	Switch light off.
		During the period ON	Switch on the light for a certain duration. The desired duration can be set, e.g. [1 hour]. The behaviour after the duration has elapsed depends on the operating mode. <ul style="list-style-type: none"> - Fully automatic: The light stays on when motion is detected. - Semi-automatic, manual operation: The light is switched off.
		During the period OFF	Switch off the light for a certain duration. The desired duration can be set, e.g. [1 hour]. NOTE: Presence detection and light control are deactivated during this period. The behaviour after the duration has elapsed depends on the operating mode. <ul style="list-style-type: none"> - Fully automatic: The light is switched on when motion is detected. - Semi-automatic: The light remains switched off. - Brightness automatic. Manual operation: The light is switched on.
		Start scene	Access the scene with the selected scene number. The scene ends when the push-button is used to switch back to [Automatic mode]. NOTE: For this function, at least one scene must be created in the [Scenes] menu. For details see <i>6.7 Scenes</i> .
		Next scene	Access the scene with the next higher scene number. The desired range of scenes can be set, e.g. scene number [3 to 5]. The sequence of accessing them would then be: 3»4»5»3»4»5...
		Stop	The current lighting situation is maintained as long as presence is detected and until the follow-up time has elapsed or until you switch back to [Automatic mode] by pressing the push-button.
Automatic mode	Return to the initial state of the current operating mode.		
No function	-		

Command	Default value	Setting values	Function
Long push-button action	Dim UP/DOWN	Dim UP/DOWN	When the button is pressed for the first time: Dim the light up to the maximum value; when the button is pressed again: Dim the light down to the minimum value.
		Dim UP	Dim the light up to the maximum value.
		Dim DOWN	Dim the light down to the minimum value.
		ON/OFF	(see above)
		ON	(see above)
		OFF	(see above)
		During the period ON	(see above)
		During the period OFF	(see above)
		Next scene	(see above)
		Stop	(see above)
		Automatic mode	(see above)
		No function	-
	Double push-button action	Automatic mode	Automatic mode
		Next scene	(see above)
		No function	-

NOTE: For the <Change over groups> function, **all three** button functions (<Single keystroke>, <Long push-button action> and <Double push-button action>) must be set to [No function]. For details see *6.9 Change over groups*.

6.11.5 Switch

Description

- The push-button inputs can also be used as external switch inputs for the <Change over groups> function. For details see *6.9 Change over groups*.
- NOTE: For the push-button input used, **all three** push button functions (<Single keystroke>, <Long push-button action> and <Double push-button action>) must be set to [No function]. For details see *6.11.4 Push-buttons*.
- Up to four switches can be connected to the push-button inputs S1-S4 of the APC with one pole.

- The number of switch inserts that can be used per APC depends on the design of each switch insert:

Switch insert	Contacts	Usable per APC
Single switch	1 NO contacts	4 piece
Double switch	2 NO contacts	2 piece


- The push-button inputs are assigned to the following switch instances of the APC:

Push-button input	Button instance	Switch instance
S1	0	4
S2	1	5
S3	2	6
S4	3	7

The assignment of instances may differ for other input devices (e.g. BMS detectors). For more details, please refer to the respective user manual.

App

You can get to the <Switch> screen from the <Parameterise devices> menu.



- When a switch instance is identified, the 🖱️🖱️🖱️🖱️ icon flashes.
- You can use the ⓘ icon to access further information.
- The ▶️ and ⬆️ buttons can be used to access or hide other settings.

Adjustable parameters

The following situations can be set for the switch position at the push-button input:

Parameter	Setting value	Effect
closed	Change over group ON	A closed switch position is passed to the <Change over groups> function.
	Change over group OFF	An open switch position is passed to the <Change over groups> function.

6.11.6 Actuator

Description

- The APC has an actuator (relay) with two-pole actuator connection K1/K2 (potential-free, max. 10 A).
- The [Actuators] function can be used for different tasks, depending on the type of component connected.
 - Relay function [Switch lighting]:
The actuator switches depending on the light output of the control gear. The actuator switches when the current light output of a group exceeds or falls below a switch-off value.
 - Relay function [Switch HVAC]:
The actuator switches depending on presence detection. The switch-on delay and the follow-up time after the last presence detection can be set. Room brightness and light output are not relevant.
 - Relay function [Standby switch-off]
The actuator disconnects control gear from the power supply as soon as it is not required. This makes it possible to reduce standby consumption in buildings. For correct functioning, the switch-on delay of the control gear must be set after standby switch-off. The switch-on delay depends on all interlocked relays and load contactors.
- Depending on the function, the following number of actuators can be used.


Function	Switch lighting	Switch HVAC	Standby Switch-off
Maximum number of actuators per group	64	1	1
Maximum total number of actuators	64	8	

i Information

As switching on the power supply and then starting automatic mode can lead to a loss of comfort, we recommend only using the standby switch-off function outside normal business hours. Use the timer function for this. For details see 6.6.5 Standby switch-off.

App

You can get to the <Actuators> screen via the <Parameterise devices> menu.



- When the actuator is identified, the icon flashes * * * * .
- You can use the ⓘ icon to access further information.
- The ▶ and ⬆ buttons can be used to access or hide other settings.

Adjustable parameters

Depending on the selected relay function, different parameters can be set:

Relay function	Connected	Parameter	Setting values	Default value
Switch lighting	230 V light or similar component	Switch-on value with increasing light output	0..100 % (in 10% steps)	0 %
		Switch-off value with decreasing light output	0..100 % (in 10% steps)	0 %
Switch HVAC	Components of heating, ventilation, air-conditioning and refrigeration	Switch-on delay	00:00 ... 24:00	00:02
		Follow-up time	00:01 ... 24:00	00:15
Standby switch-off	DALI control gear	Switch-on delay: Time from switching on the power supply until commands can be sent to the control gear via the DALI bus	100 ms - 2000 ms	450 ms

Information

To use standby switch-off, the function must be configured in the group the relay is assigned to. For details see [6.6.5 Standby switch-off](#).

NOTE: When switching between relay functions, the manually set values are reset to the default values.

6.12 Central button function

Description

- Push-buttons can be used for the central control of all groups.
- Push-buttons for a central button function must not be assigned to a group.
- The following functions can be assigned to a button:
 - [Central ON]: Lighting is switched on with an adjustable light output in all groups.
 - [Central OFF after AUTOMATIC end]: All groups are switched off if no automatic operation is active.
 - [Central AUTOMATIC]: All groups switch to automatic mode.
 - [Central ON/OFF]: In all groups, lighting with an adjustable light output is switched on or off.
- Operation with a central button function takes precedence over button functions of a group. A group cannot be switched off if it is switched on with the central button function.

Requirements

- Groups have been created.
- At least one button not assigned to a group is available.

App

You get to the <Central button function> via the Setup Wizard.

1. Tap the <ADD BUTTON> button.
2. Select an available button.
3. Select a button function.
4. If the button function [Central ON] or [Central ON/OFF] is selected, set a light output for all groups.
 - » The central button function has been configured.

7 Products section


7.1 Products

Description

The <Products> menu allows you to manage all customisable ESYLUX products and find related information and documents.

App

To get to the <Products> menu, tap the <Select products and configure>  button on the home screen. .




– Screen without Bluetooth connection




– Screen with active Bluetooth connection

The <Products> menu shows the products already entered in the app.



- An APC that has already been connected is automatically included in the list.
- You can use the <Add product>  button to add a configurable product that cannot be configured directly via Bluetooth. You can add a new product by barcode (on the product packaging) or search in the manufacturer database. This requires internet access.
- In the list of products, tap the product you would like more information about.



Do not use the <Configure>  button to configure an APC. Use the <Settings> menu for this. The <Configure>  button in the Products section is used to configure devices without Bluetooth using the ESY-Pen. An APC can only be configured here if the app is connected to it via Bluetooth. For details see *6.2 Setup Wizard*.

The following documents are available on this screen:

- Information about the product
 - Documents about the product
- This requires internet access.

8 Projects section

8.1 Overview

About projects

In the <Projects> section, you can save the configuration of ESYLUX products in a building. You can export the saved configuration and restore it later if required. The configuration can also be exported as a PDF file for reference purposes.

You can access the <Projects> section by clicking on [CREATE AND MANAGE PROJECTS] on the start screen.

<Projects> screen



This screen displays a list of existing projects. You can import saved or exported projects and create a new project.

To delete a project, drag it to the left and tap the waste bin icon.

Icon	Comment
	Tap the magnifying glass to search for a project name.
	Tap on the icon or on the name of the project to open the project.
	Tap on the icon to import a saved or exported project.
	Tap on the icon to create a new project.

8.2 Create project

Requirement


- The app is connected to the presence detector.

Procedure

1. Tap the [New project] icon on the <Projects> screen.




2. Tap on <New project> and enter a name for the project.



3. Enter an optional description for the project.
4. Tap on the [+] to add a floor. Enter a name or tap on the [+] behind <Pre-selection> to select a predefined name. Confirm with [OK].

5. Tap on the [+] to add a room on the selected floor. Enter a name. Confirm with [OK].
6. Tap on the [+] to add a device. Then tap on [New device]. Enter a name. Tap on the [+] behind <Select device> to select an ESYLUX product. Select the device currently connected. The configuration of the presence detector synchronises with the project. Confirm with [OK].



» The project has now been created.

Options

- You can add more floors, rooms and devices. To do this, tap on the respective [+].
- To select an element for editing from several floors, rooms or devices, tap on the name.
- To change the name of a floor, room or device, tap the appropriate pencil icon.
- You can have the number of floors, rooms and appliances displayed for the project. You can also create, display and edit notes. To do this, tap on [>] next to the name of the project, then on [Details] or [Notes].
- To remove a floor, a room or a device from the project, tap on the appropriate [-].
- To add a device that is not configured via Bluetooth, select a favourite item on the <Products> selection screen or tap on [Add product]. You can now scan the barcode of your product or search for your product in the ESYLUX database.

8.3 Change device settings in the project

Synchronise device settings with the project

For ESYLUX devices configured via Bluetooth, the settings saved in the device can be synchronised with the project.

Requirement

- The device is connected to the ESY app.

Procedure

1. Open the project in which the device is used.
 - » A prompt appears asking whether the project should be updated with the device settings.
2. Confirm the prompt.
 - » The project is now synchronised with the device settings.

Edit settings of a device configurable via Bluetooth in the project

Requirement

- The device is connected to the ESY app.

Procedure

1. Open the project in which the device is used.
2. Select a floor, a room and the connected device.
3. Tap on [Configure].
 - » The <Settings> menu opens. For details see *6 Settings menu*.
 - » Once you have made the required settings, you can open the project again to synchronise it with the new settings.

Edit settings of a device configurable via infrared in the project

Requirement

- No device configurable via Bluetooth is connected to the app. "No connection" must appear under the button .

Procedure

1. Open the project in which the device is used.
2. Select a floor, a room and a device configurable via infrared.
3. Tap on [Configure].
4. Refer to the operating instructions for the specific product for further information.

8.4 Export and import project

Export project as PDF file

You can export your project as a PDF file to save it for reference or print it out. To do this, proceed as follows:

1. Open the project.
2. Tap on [>] next to the name of the project. A menu appears.
3. Select [PDF].
 - » A save dialogue opens on a mobile phone with Android. Select a file name and location to save the PDF file here. On an iPhone, the PDF file is saved on your iPhone in the ESY Control/ESY-Control_Exports folder without prompting you.
 - » You can then send or print the PDF file using the features of your mobile phone.

Export project as json file

You can export your project as a json file to save it in another location and import it again later if required. To do this, proceed as follows:

1. Open the project.
2. Tap on [>] next to the name of the project. A menu appears.
3. Select [Share].
 - » The share dialogue opens on your mobile phone. Send or save the json file as required.
 - » You can later import the json file on this or another mobile phone to restore the project.

Import project as json file

You can import an exported project again. The json file must be saved in a location that can be accessed by your mobile phone's Files app. Proceed as follows to import:

1. Tap on the [Import project] icon on the <Projects> screen.
2. Tap on [SELECT PROJECT FILE].
3. Select the required json file.
4. Tap on [IMPORT].
 - » The project is imported and appears in the list of your projects.

9 Menu information


Description



Pressing the  button opens the Information menu.

- General information and settings for the app are available in this menu.

App



The following information and settings are available in this menu:

- **Contact form**
This requires internet access.
 - Contact
 - Newsletter registration
 - ESYLOCATOR
- **Provisions of use**
This requires internet access.
 - Privacy Policy
 - Disclaimer
- **Terms and conditions**
This requires internet access.
 - Terms and conditions
 - Terms of delivery and payment

- **Options**
 - "ESYLUX internal" section
 - Current app version
- **Imprint**

This requires internet access.

 - Imprint
 - Photo credits

10 FAQ

10.1 What does this APC indicator mean?

The LED indicators of the APC that light up occasionally provide useful information.

- Various states and situations of the configuration can be identified by the colour and the flashing behaviour of the integrated LED. For details see *5.1.5 APC LED indicators*.

10.2 What does this app indicator mean?

The app's indicators and messages that appear in special situations provide explanation and help.

Indicator/Notification	Meaning/ Remedy/ Comment
 "No connection"	<ul style="list-style-type: none"> - APC not paired with mobile device (Bluetooth). - APC out of Bluetooth range (10 m). - APC without voltage.
No entries on the <Bluetooth device overview> screen	<ul style="list-style-type: none"> - APC already paired with other mobile device. - APC out of Bluetooth range (10 m). - APC without voltage.
Window <Bluetooth pairing request>	<ul style="list-style-type: none"> - Enter the PIN code of the device.
"No connection"	<ul style="list-style-type: none"> - APC out of Bluetooth range (10 m). - APC without voltage.
"No ESYLUX devices"	<ul style="list-style-type: none"> - APC out of Bluetooth range (10 m). - APC without voltage.
"Bluetooth must be enabled to use the app"	<ul style="list-style-type: none"> - Bluetooth switched off on the mobile device. - APC without voltage.
"Establishing Bluetooth connection"	<ul style="list-style-type: none"> - Please wait until the connection is established.
"Retrieving data from the detector"	<ul style="list-style-type: none"> - Please wait until the data is synchronised (approx. 60 s).
"Checking the software version"	<ul style="list-style-type: none"> - Please wait until the software version has been checked.
"New APC software version available"	<ul style="list-style-type: none"> - The APC software can be updated.
"Do not receive update notice on connection" (checkbox)	<ul style="list-style-type: none"> - Tick the checkbox if the app is to be updated in the background.
"Restricted offline access"	<ul style="list-style-type: none"> - No internet connection. This only affects some special functions of the app, not communication with the device.

Indicator/Notification	Meaning/ Remedy/ Comment
"The device is already set up. [...] Exit Setup Wizard."	– If the device is to be completely reconfigured: Reset to factory settings.
"Software update ready for installation" (banner insertion)	– Notification of the mobile device operating system (Android or iOS), referred to as "software" here.

10.3 Why is a function or setting unavailable or greyed out?

All required instances must be assigned to the respective group and set up correctly. For minimum constellations for the operating modes, see *5.1.4 Minimum constellations*.

- Check the assignment of instances to groups, see *6.5 Create groups*.
- Check the setup of the required devices, see *6.11 Parameterise devices*.

10.4 How is the time set in the APC?

During operation of the APC, the internal clock may become increasingly inaccurate. This results in slight deviations in time-controlled functions.

- Use the ESY app to connect to the APC. When the connection is established, the app automatically synchronises the time on the APC with the time on the device.
- In Europe, the APC automatically changes to daylight saving time and back to standard time at the correct time.

11 Decommissioning

11.1 Disassembly

To disassemble the product, work on the 230 V mains is required. This may only be carried out by electrical fitters or qualified electricians.

After disconnecting from the 230 V mains, further work can also be carried out by persons without electrical engineering qualifications.

11.2 Disposal

This product must not be disposed of with unsorted residual waste. Owners and operators of the product are legally obliged to dispose of all parts of the product properly and according to type:

- Electrical and electronic parts as well as cables belong to the category of electrical waste.
- Packaging, cardboard boxes, moulded parts and foils belong to the respective material recycling category.

You can get further information from your city or municipal administration.

12 APPENDIX

12.1 Abbreviations

APC (DALI-2)	Product name
BLE	Bluetooth Low Energy: Bluetooth radio technology
BMS (DALI-2)	Product name
bt	Bluetooth
DA+/DA-, DA1/DA2	DALI-2 bus connection
ECG	Electronic control gear
FAQ	Frequently asked questions and the answers to them
GTIN	Global Trade Item Number: Identification number for trade items
HVAC	Heating, ventilation, air conditioning/refrigeration technology
K1/K2	Actuator connection (for external lighting, HVAC etc.)
LVK	Light distribution curve
lx	Lux: unit of illuminance
MD	Motion detector
OM	Operating mode
OTA	Over-the-air: radio interface (for software updates)
PD	Presence detector
PIR	Presence detector sensor technology
PS	(Bus) power supply
S1, S2, S3, S4	Push-button/switch connections
TS	Light sensor
UID	Unique Identifier: Identification number for data objects

12.2 Glossary

Actuator	Switch for switching devices on and off. The APC has a built-in actuator with potential-free contacts. An actuator can be used for the following functions: <ul style="list-style-type: none"> - 230 V lighting - HVAC - Standby switch-off of control gear
Address	Unique identifier of a bus device (device/instance) in the DALI-2 bus
APC	ESYLUX term for "application controller"
Automatic mode	Button function: Return to the initial state of the current operating mode
BlueMode	ESYLUX term for a special configuration state of the control system
Bluetooth connection	Strictly speaking, two different techniques: <ul style="list-style-type: none"> - Pairing: initial authentication - Connection ("bonding"): for regular data exchange
Bluetooth Low Energy (BLE)	Bluetooth technology with low power consumption
BMS	here: ESYLUX term for a presence detector general: abbreviation for building management system
Button function	Different types of push-button actuation can be interpreted by the control system: <ul style="list-style-type: none"> - Single keystroke - Long push-button action - Double push-button action
Configure; Parameterise	The parameterisation of the devices is a subset of the entire configuration (devices, groups, scenes, etc.).
Control gear	DALI term for the ECG of a light
DALI; DALI-2	Interface standard/ control protocol: DALI for lighting technology, DALI-2 for building technology; DALI-2 includes DALI
Default setting, factory setting	Configuration state at delivery and after resetting the APC
Default value	Value of a parameter in the default setting
Device	here: DALI-2 component such as APC, control gear, push-button etc.
ECG	Control gear of a light
Follow-up time	Time between the last presence detection and the next control state
Group	Combination of several devices (operating and input devices); can include all or only specific lights in a room
HVAC	Here: Components of heating, ventilation, air-conditioning and refrigeration

IEC 62386-xxx	Series of standards for the concept and components of DALI-2
Instance	Sub-component of a device that fulfils its own function (e.g. presence detection or brightness measurement). Each instance in the DALI-2 bus can be uniquely addressed via the device and the instance number.
Light control	Lighting is controlled to a constant brightness level – depending on the amount of daylight.
Manual override (by dimming)	Manual brightness setpoint adjustment: If dimming is done manually during light control, the new brightness value in the room is permanently adopted as the new brightness setpoint. Requirement: Push-button for dimming UP/DOWN is defined.
Operating mode	Control mode: fully automatic, semi-automatic (manual start) or manual only
Option; optional	Not strictly required, not included in the scope of supply of this product or only available as an accessory.
Participant, bus participant	here: Device/instance in the DALI-2 bus
Presence; motion	Literally speaking, a presence detector only detects presence, a motion detector also detects the direction of motion. In fact, it makes no difference in the application.
Product	here: APC
Push-button; switch	Push-buttons and switches can be connected directly to the APC or integrated into the DALI-2 bus via other devices. Push-buttons are used for various control tasks, e.g.: <ul style="list-style-type: none"> - manual operation or override - scene access Switches are used to change over groups.
Scene	Function that switches on one or more groups with constant, adjustable light output at the touch of a button
Setting values	Possible range of values or selection values for a parameter
Software	here: APC Firmware



ESYLUX GmbH
An der Strusbek 40
22926 Ahrensburg
Germany

Phone: +49 4102 489-0
E-mail: info@esylux.com
Internet: www.esylux.com